

NOTES:

- WHERE FIRE HYDRANT IS SHOWN BEHIND SIDEWALK, SET CENTER OF HYDRANT 2 FEET BEHIND WALK.
- 2. FIRE HYDRANT LINE SIZE SHALL BE A MINIMUM OF 8 INCH DIAMETER IF LENGTH IS GREATER THAN 50 FEET.

CITY OF REDMOND, WASHINGTON

APPROVED BY: RON GRANT

REVISION DATE: MARCH 01, 2010

CITY ENGINEER





STANDARD DETAILS

FIRE HYDRANT ASSEMBLY

FILE NAME: SD713 DWG

DETAIL NUMBER: 713