

IPS = IRON PIPE SIZE FIP = FEMALE IRON PIPE THREAD MIP = MALE IRON PIPE THREAD

## NOTES:

- 1. CORPORATION STOP SERVICE CONNECTIONS SHALL ONLY BE USED FOR SINGLE SERVICES UP TO 2 INCH METER SETTERS AND DOUBLE SERVICES UP TO 1 INCH METER SETTERS. FOR TRIPLE AND QUADRUPLE MANIFOLDS, REFER TO STANDARD DETAIL 701B GATE VALVE SERVICE CONNECTIONS.
- 2. SERVICE CONNECTION PIPE SIZE SHALL BE 2 INCH DIAMETER UNLESS OTHERWISE SHOWN ON THE CONSTRUCTION DRAWINGS.
- 3. ATTACH 12 GAUGE TRACER WIRE TO WATER MAIN TO MAKE ELECTRICALLY CONTINUOUS.
- 4. SERVICE PIPE SHALL BE BURIED IN PEA GRAVEL.
- 5. DIRECT TAPPING OF WATER MAIN IS NOT ALLOWED.

CITY OF REDMOND, WASHINGTON

APPROVED BY: RON GRANT

REVISION DATE: MARCH 01, 2010

CITY ENGINEER





STANDARD DETAILS

CORPORATION STOP SERVICE CONNECTIONS