

IRRIGATION METER PLAN

NOTES:

- EXEMPT METERS SHALL BE PLACED GENERALLY PARALLEL WITH THE CITY WATER MAIN AND PERPENDICULAR TO THE CITY METER.
- 2. EXEMPT METERS SHALL BE PLACED A MINIMUM OF 12 INCHES FROM CITY WATER METER AND SHOULD GENERALLY NOT BE MORE THAN 18 INCHES.
- INSTALL EXEMPT METER SETTER IN ACCORDANCE WITH STANDARD DETAIL 702...

CITY OF REDMOND, WASHINGTON

APPROVED BY: RON GRANT

REVISION DATE: MARCH 01, 2012

CITY ENGINEER





STANDARD DETAILS

EXEMPT IRRIGATION METER LOCATION REQUIREMENTS

FILE NAME: SD719.DWG

DETAIL NUMBER: 719